

**SPECIAL BOARD OF HEALTH
MINUTES
February 25, 2019**

This meeting was advertised in The Express Times, notice posted in the Alexandria Township Municipal Office, and the Alexandria Township website (www.alexandrianj.gov) as required by the Open Public Meetings Act.

Meeting Called to Order at 6:01 PM.

ROLL CALL:

PRESENT: Chair Pfefferle, Comm. Kiernan, Mayor Garay

ABSENT: None

NEW BUSINESS:

**A.) Septic Waiver
B-15.01, L-8.70
37 Alexandria Drive**

Kurt Hoffman, PE of Kurt Hoffman Engineering, LLC was present for the above property. The Hunterdon County Health Department received an application for a septic alteration plan to correct a malfunctioning system to an existing 4 bedroom dwelling with no expansion by the use of an Ecoflo Coco Filter 600P Pack. The current septic failed a home inspection report due to a home sale. One waiver is needed to be approved by the Alexandria Township Board of Health as noted in correspondence from the Hunterdon County Health Department dated February 20, 2019. Mayor Garay made a motion, seconded by Comm. Kiernan to approve the following waiver:

1. Alexandria Township Board of Health ordinance requires all systems be designed for 1.61 ft²/gpd. The engineer has designed an Advanced Treatment Unit which allows the system to be designed for 1.233 ft²/gpd. which is equivalent to a K4 permeability rate. Engineer shall explain the reason for the reduction to the satisfaction of the Board.

Roll Call: Aye: Garay, Kiernan, Pfefferle

Nay: None

Abstain: None

Motion Carried

COMMENTS FROM THE FLOOR:

None

MOTION TO ADJOURN

Mayor Garay made a motion, seconded by Comm. Kiernan to adjourn.

Roll Call: Aye: Garay, Kiernan, Pfefferle

Nay: None

Abstain: None

Motion Carried

Meeting Adjourned at 6:11 PM.

Michele Bobrowski, Board Secretary